

### **Flexible Duct Connector**

Provide and install flexible duct connector as manufactured by Ward Industries as shown on plans and at inlet and discharge of all air handling equipment (unless otherwise noted). Flexible duct connector shall meet or exceed the requirements of NFPA 90A and be constructed of a UL Classified coated fabric preassembled with steel or aluminum flanges. Fabric and metal shall be joined by means of a double lock seam or single lock seam shielded with metal on both sides. Specifier to reference Ward flexible duct connector specification sheet for specific properties of each fabric.